

# EC1504

## Heat pump water heater performance

**Author:** Andrew Pollard \_\_\_\_\_  
Building Physicist (Energy in Buildings)

**Reviewer:** Michael Babylon \_\_\_\_\_  
Scientist

**Contact:** BRANZ Limited  
Moonshine Road  
Judgeford  
Private Bag 50908  
Porirua City  
New Zealand  
Tel: +64 4 237 1170  
Fax: +64 4 237 1171  
[www.branz.co.nz](http://www.branz.co.nz)

BRANZ's agreement with its Client in relation to this report contains the following terms and conditions in relation to **Liability and Indemnification**

- a. Limitation and Liability
- i. BRANZ undertakes to exercise due care and skill in the performance of the Services and accepts liability to the Client only in cases of proven negligence.
  - ii. Nothing in this Agreement shall exclude or limit BRANZ's liability to a Client for death or personal injury or for fraud or any other matter resulting from BRANZ's negligence for which it would be illegal to exclude or limit its liability.
  - iii. BRANZ is neither an insurer nor a guarantor and disclaims all liability in such capacity. Clients seeking a guarantee against loss or damage should obtain appropriate insurance.
  - iv. Neither BRANZ nor any of its officers, employees, agents or subcontractors shall be liable to the Client nor any third party for any actions taken or not taken on the basis of any Output nor for any incorrect results arising from unclear, erroneous, incomplete, misleading or false information provided to BRANZ.
  - v. BRANZ shall not be liable for any delayed, partial or total non-performance of the Services arising directly or indirectly from any event outside BRANZ's control including failure by the Client to comply with any of its obligations hereunder.
  - vi. The liability of BRANZ in respect of any claim for loss, damage or expense of any nature and howsoever arising shall in no circumstances exceed a total aggregate sum equal to 10 times the amount of the fee paid in respect of the specific service which gives rise to such claim or NZD\$50,000 (or its equivalent in local currency), whichever is the lesser.
  - vii. BRANZ shall have no liability for any indirect or consequential loss (including loss of profits).
  - viii. In the event of any claim the Client must give written notice to BRANZ within 30 days of discovery of the facts alleged to justify such claim and, in any case, BRANZ shall be discharged from all liability for all claims for loss, damage or expense unless legal proceedings are commenced in respect of the claim within one year from:
    - The date of performance by BRANZ of the service which gives rise to the claim;
    - or
    - The date when the service should have been completed in the event of any alleged non-performance.
- b. Indemnification: The Client shall guarantee, hold harmless and indemnify BRANZ and its officers, employees, agents or subcontractors against all claims (actual or threatened) by any third party for loss, damage or expense of whatsoever nature including all legal expenses and related costs and howsoever arising relating to the performance, purported performance or non-performance, of any Services.
- c. Without limiting clause b above, the Client shall guarantee, hold harmless and indemnify BRANZ and its officers, employees, agents or subcontractors against all claims (actual or threatened) by any party for loss, damage or expense of whatsoever nature including all legal expenses and related costs arising out of:
- i. any failure by the Client to provide accurate and sufficient information to BRANZ to perform the Services;
  - ii. any misstatement or misrepresentation of the Outputs, including Public Outputs;
  - iii. any defects in the Products the subject of the Services; or
  - iv. any changes, modifications or alterations to the Products the subject of the Services.

# Heat pump water heater performance

## 1. CLIENT

Parex Industries Limited  
103 Central Park Drive  
Waitakere 0610  
New Zealand

## 2. OBJECTIVE

Parex Industries requested BRANZ to collect performance data on three Stiebel Eltron heat pump water heater (HPWH) systems located in Auckland, Wellington and Christchurch. The three HPWH systems were monitored for a year to allow the HPWH systems to experience a range of environmental conditions and to allow for characteristic annual performance to be assessed. BRANZ was also asked to provide weather data from the NIWA Cliflo database for suitable locations over the monitored period.

## 3. METHOD

Each HPWH was instrumented as indicated in Figure 1. A thermocouple logger was used to record the hot and cold water temperatures. The water use of the system was measured by a Manuflo MES-MR water meter with a pulsed output of 34 pulses per Litre and a Siemens S2AS electricity meter with a pulsed output for each Watthour of electrical energy consumption of the HPWH unit. The pulsed outputs of both the water meter and the electricity meter were recorded by BRANZ pulse loggers recording at six minute intervals.

ARP

WMB



Report Number: EC1504

Date of Issue: 20 October 2009

Page 3 of 10 Pages




Figure 1 Monitoring arrangement for each HPWH

## 4. COMPILING DATA

The raw data files from each of the loggers were processed to convert the thermocouple responses to actual temperatures and the pulses to either electrical demand (in Watts) or water demand (in Litres per minute) over the corresponding six minute interval.

The collected data from each of the systems is provided in the Microsoft Excel (2007) datafiles;

**ah3.xlsx** for the Auckland system

**wh1.xlsx** for the Wellington system

**ch1.xlsx** for the Christchurch system

The data is labelled;

**dhwE** for the electrical energy demand (watts) over the logging interval,

**dhwF** for the water flow (litres per minute) over the logging interval,

**cldT** for the cold water inlet temperature at start of the logging interval,

**hotT** for the hot water outlet temperature at start of the logging interval,


**huvT** for the temperature of the logger at the start of the logging interval.

A broad overview of the data in these files is provided in the graphs given in Appendix A.

While the logger temperature (huvT) measured for each site provides an approximate indication of the temperature at each site, its measurement does not follow meteorological practices. To provide some correspondence to measured weather data, temperature and humidity data was retrieved from the NIWA Cliflo database. The sites chosen were of major climate stations close to the measurement site. The sites used were Whenuapai (NIWA Agent Number 23976) for the Auckland system, Wellington Airport (NIWA Agent Number 3445) for the Wellington system and Kyle Street (NIWA Agent Number 24120) for the Christchurch system.

Data was downloaded for the period from 1 April 2008 to 23 September 2009 to cover the analysed monitoring period of all the sites. The data is provided in the Excel 2007 file **WeatherData.xlsx**.

Figure 2 shows a timeline of the period of data collection from each of the HPWH systems and the period of weather data sourced. The period of data collection for the HPWH systems is shown in blue with the darker blue colour indicating the period of analysis undertaken in section 5. The weather data was compiled for the period shown in red and covers the period of analysis for all three of the sites.



**Figure 2 Measurement collection period for the three sites (blue) with the period of weather data (red)**

## 5. RESULTS

The peak in temperature of the measurement from the outside of the water pipe is slightly delayed from when the water is drawn-off from the cylinder. Therefore, the response from the thermocouples need to be offset one measurement step when it is used in calculations.

The energy contained in the water drawn-off from the HPWH was calculated every six minutes from the product of the temperature difference of the outgoing to the incoming water, the volume of water drawn-off and the volumetric heat capacity of water.

The average of the available data of the measured volume of hot water, the measured electrical energy of the HPWH system and the calculated energy content of the drawn-off water over one year is shown in Table 1. Also shown in Table 1 is the coefficient of performance (COP) of the each of the systems which is calculated as;

$$COP = \frac{Q_{draw\ off}}{E_{ne}} \quad (5.1)$$

where  $Q_{draw\ off}$  is the energy content of the drawn-off water

$E_{ne}$  is the non-environmental energy (ie the electrical input energy) to the HPWH system

In comparing COP values it is important to consider what values are achieved by reference systems. For electric storage cylinders the standing losses can be a sizable proportion of the heat loss of the system. Results from the HEEP project indicate that average standing losses are of the order of 33% of total water heating energy leading to COP for an average electric storage cylinders of 0.67. A system with a COP of 1.34 would therefore require half as much water heating energy as a standard electric storage cylinder for a given amount of hot water.

**Table 1 Performance of the HPWH systems**  
(all data to two significant figures)

System	Hot Water use (Litres / day)	Draw-off Energy (kWh / year)	Electrical Energy (kWh / year)	COP
Auckland	100	1700	1500	1.2
Wellington	180	3400	1900	1.8
Christchurch	170	2700	1900	1.5

## 6. APPENDIX A: EDA GRAPHS

To examine the extensive amount of data present, it is convenient to use Exploratory Data Analysis (EDA) graphs to allow a broad overview of the data to be seen. EDA plots of the systems are given in Figure 3, Figure 4 and Figure 5 with the following providing an overview of the graphs.

The channel label appears in the title of the graph: The first three characters are the site location either Auckland (**ah3**), Wellington (**wh1**) or Christchurch (**ch1**). The rest of characters indicate what is displayed in the series of three panels under the title. **dhwE** is the non-environmental electricity usage of the HPWH system; **dhwF** is the cold water flow into the HPWH system; **hotT** is the temperature of the hot water outlet; **cldT** is the temperature of the cold water inlet to the HPWH system and **huvT** is the temperature of the logger which can be used as an approximate measure of ambient conditions close to the system.

Underneath the channel label is summary information. This reports the number of days monitored, the number of days of NAs (missing values), then the percentage of valid data points with values in the ranges: equal to zero; greater than zero and less than 20; greater than 20; and finally the energy use (kWh) over a year (one average day x 365) is provided for electricity channels or the average temperature for temperature channels.

Each individual EDA graph contains three plots: a **histogram**, a **time-series plot** and a **daily profile** of the data recorded every six minutes.

The **histogram** shows how often the data was in a given range. The data range is given on the horizontal axis and the counts are on the vertical axis. For appliances that have too many values in the 'zero' bin, this bin is replaced by a number, otherwise the remaining bins would be too small to see clearly.

The **time-series plot** has the date (start of month) on the horizontal axis (below the daily profile graph), and the data value on the vertical axis. As there is so much data, the lines sometimes overlap slightly, causing a solid block of black. This indicates rapid switching between high and low values. If a solid block has an apparent straight edge on the top or bottom, and this indicates that it is switching to a constant value. If the solid block has a ragged edge, it is switching to a changing value. Periods of missing values are indicated by a heavy blue straight horizontal line near the top of the time-series plot.

The third plot contains two separate plots. The plot shown in red is the average **daily profile** for the respective channel averaged over the complete set of data. The left of this profile is midnight and early morning, to midday in the middle and evening on the right hand side of the plot. The other plot is shown in black is a **moving average** of the data. This moving average plot uses the same time axis as for the second time-series plot which can be read from directly below the graph.




Figure 3 EDA plots for the Auckland system




Figure 4 EDA plots for the Wellington system




Figure 5 EDA plots for the Christchurch system